

City of Las Vegas Code and Interpretation

AMEND: 25

DATE: December 19, 2008

CODE: 2006 IBC ☐ 2005 NEC ☐ Local Amendments ☐
 2006 IRC ☐ 2006 UMC ☒ POOL CODE ☐
 2006 IECC ☐ 2006 UPC ☐ MISC. ☐ Admin Code

CODE SECTION: UMC 904.10.3

TOPIC: Roof access ladders

PURPOSE/REASON: Roof access ladders are to be installed in a common accessible area such as a fire riser room, mechanical room or an electrical room provided minimum clearances are available. In multistory buildings the access ladders shall be located in the stairway.

INTERPRETATION: Roof access ladders shall be located in or at a common accessible area as noted in the proposal.

Approved: Chris Knight, CBO